

Declaration of Conformity

Date of Issue: 7th April 2016

Manufacturer: Tekron International Ltd

Address: Level 1, 409 Cuba Street
 Alicetown
 Lower Hutt, 5010
 New Zealand

Model Number: PRPTP Translator.

Declaration:

This certificate declares that the equipment described above complies with the applicable requirements of the following directives:

Approvals and Certification

<i>COMPLIANCE</i>	<i>APPLICABLE COUNCIL DIRECTIVE</i>	<i>ACCORDING TO</i>
CE compliance	Low voltage directive	EN60950-1:2003
ISO	Manufactured under a registered quality program	ISO 9001:2008

Type Tests

<i>TEST</i>	<i>REFERENCE STANDARD</i>	<i>LEVEL</i>	<i>Notes</i>
Electrostatic Discharge	EN 61000-4-2:2008	Level 2 (Contact) Level 4 (Air)	
Electromagnetic field immunity	EN 61000-4-3:2008 IEC 60225-26: 2013	Level 3	
Fast Transient Disturbance	EN 61000-4-4:2004	Level 3 (power) Level 4 (signal)	
Surge Immunity	EN 61000-4-5:2005	Level 3	
Magnetic Field Immunity	EN 61000-4-8:2010		30 A/m
Pulse Magnetic Field Immunity	EN 61000-4-9:2000		1000 A/m (8/20us)
Voltage Dip & interruption	EN 61000-4-29:2000		
Radiated & Conducted Emissions	CISPR22:2006, EN 61000-6-4:2006	Class A	150 kHz to 1 GHz
Cold Test	IEC 60068-2-1 IEC 61850-3	-20°C, 72 hours	
Dry Heat	IEC 60068-2-2 IEC 61850-3	60°C, 72 hours	
Change of Temperature	IEC 60068-2-14 IEC 61850-3	-20°C to 60°C, 3 hours dwell	
Damp heat, cyclic (12 h + 12 h cycle)	IEC 60068-2-30 IEC 61850-3	55°C and 25°C, 95% humidity, 7 cycles	
Damp heat, Steady state	IEC 60068-2-78 IEC 61850-3	45°C, 95% humidity, 96 hours	

I hereby declare that the product to which this declaration of conformity relates complies with the mentioned standard(s), and all products supplied under this Declaration will be identical to the sample identified in this Declaration.

Signed



Signatory

Jared Laverty

Position

Technical Manager